



सत्यमेव जयते

Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
First Floor of Midnapur Fire Station Sepoy Bazar, P.O.: Medinipur, P.S.: Kotwali, Pin:- 721101

Memo No.:FSR/0125186231500361

Date : 21-03-2025

From :
Divisional Fire Officer
Paschim Medinipur,
West Bengal Fire & Emergency Services

To :
DAV PUBLIC SCHOOL MIDNAPUR
MOUZA - NARAMPUR, DAAK BUNGLOW ROAD, J.L. NO. - 174, R.S. PLOT NO. - 8(P), L.R. PLOT NO. - 205(P),
HOLDING NO. - G -353, P.S. - MEDINIPUR, DIST - PASCHIM MEDINIPUR, PIN - 721101
Sub : Fire Safety Certificate for an Existing 2(Two) nos. Building of G+I & G+II storied School Building (i.e. Building – 1, G+I storied and Building – 2, G+II storied building), in the name of “DAV PUBLIC SCHOOL, MIDNAPORE” under group of Educational at Mouza - Narampur, Daak Bungalow Road, J.L. No. - 174, R.S. Plot No. - 8(P), L.R. Plot No. - 205(P), Holding No. - G -353, P.S. - Medinipur, Dist - Paschim Medinipur, Pin - 721101.

This is in reference to your AIN 211892506300005030 dated 07-Feb-2025 regarding Fire Safety Certificate for an Existing 2(Two) nos. Building of G+I & G+II storied School Building (i.e. Building – 1, G+I storied and Building – 2, G+II storied building), in the name of “DAV PUBLIC SCHOOL, MIDNAPORE” under group of Educational at Mouza - Narampur, Daak Bungalow Road, J.L. No. - 174, R.S. Plot No. - 8(P), L.R. Plot No. - 205(P), Holding No. - G -353, P.S. - Medinipur, Dist - Paschim Medinipur, Pin - 721101..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

1. All the Fire Safety Recommendation which was issued vide this office Memo No. FSR/0125186231500361, Date-05.02.2024 to be followed strictly at all times.
2. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No perking will be allowed on the driveway.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300005030

3. Directional sign and escape route shall be displayed prominently.
4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
5. The interior finish decoration of building shall be made with low flame spread material confirming I.S. Specification.
6. The notice of Fire Fighting and Evacuation with "Exit Sign" from the building shall be prepared and displayed at all vulnerable places of the building.
7. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing
8. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
9. First – Aid Fire Fighting system shall be provided as per I.S Specification.
10. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
11. If required the old line shall have to be replace with new line the cables shall always be laid in M.S. conduct pipes continuously bounded to the earth.
12. Periodical flashing of water from the Hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
13. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
14. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling and ducts.
15. A Fire control room with close circuit T.V. system will have to be installed which will observe all the floor of the building.
16. Transformer and Switch Gear room shall be protected with automatic CO2 or D.C.P. Fire extinguisher conforming I.S. Specification.
17. A Fireman shall be maintained round the clock for safety of the building.
18. This Fire Safety Certificate is valid for Three (03) years and has to be renewed every three year from the date of issue of this letter.
19. Each three year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all the Life & Fire Safety arrangements and installation of the building.

N.B: No addition and alteration without prior permission of West Bengal Fire & Emergency Services. Otherwise the Fire Safety certificate will be treated as cancelled.

Valid Upto : 19-Mar-2028



Signature valid

Digitally Signed.
Name: Ban Kumar Chowdhury
Date: 21-Mar-2023 19:36:28
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300005030